AUGUST 1, 2016

REPAIR TO (RE)MOVE INTERIOR VERTICAL MEMBER

MII-REP20

MiTek USA, Inc. Page 1 of 1




1. THIS IS A SPECIFIC REPAIR DETAIL TO BE USED ONLY FOR ITS ORIGINAL INTENTION. THIS REPAIR DOES NOT IMPLY THAT THE REMAINING PORTION OF THE TRUSS IS UNDAMAGED. THE ENTIRE TRUSS SHALL BE INSPECTED TO VERIFY THAT NO FURTHER REPAIRS ARE REQUIRED. WHEN THE REQUIRED REPAIRS ARE PROPERLY APPLIED, THE TRUSS WILL BE CAPABLE OF SUPPORTING THE LOADS INDICATED.

2. ALL MEMBERS MUST BE RETURNED TO THEIR ORIGINAL POSITIONS BEFORE APPLYING REPAIR AND HELD IN PLACE DURING APPLICATION OF REPAIR.

3. THE END DISTANCE, EDGE DISTANCE, AND SPACING OF NAILS SHALL BE SUCH AS TO AVOID SPLITTING OF THE WOOD.

4. LUMBER MUST BE CUT CLEANLY AND ACCURATELY AND THE REMAINING WOOD MUST BE UNDAMAGED.

5. THIS REPAIR IS TO BE USED FOR SINGLE PLY TRUSSES IN THE 2X_ORIENTATION ONLY. 6. CONNECTOR PLATES MUST BE FULLY IMBEDDED AND UNDISTURBED.



TRUSS CRITERIA

LOADING: 40-10-0-10 (MAX) **DURATION FACTOR: 1.15**

TRUSS SPACING : 24" MAXIMUM CHORD SIZE : 2X 4 OR LARGER (NO 2 MIN GRADE)

TOP CHORD PITCH : 3/12 - 12/12 BOTTOM CHORD PITCH: 1.5/12 - 8/12

REFER TO INDIVIDUAL TRUSS DESIGN FOR PLATE SIZES AND LUMBER GRADES